

# MAS Certified Green® Certificate of Compliance Low-Emitting Materials



Awarded to: **NICHIHA USA, INC. OF JOHNS CREEK, GA**  
6465 E. JOHNS CREEK CROSSING, SUITE 250: ZIP CODE: 30097

Category: Construction Materials - Wall Products  
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom & private office*

\*Conforms With: Criteria of MAS Certified Green® Program *low-emitting materials*  
LEED v4.1 ID+C, BD+C *low-emitting materials*  
LEED TVOC Emissions at 14-days (*classroom setting*) *0.5 mg/m<sup>3</sup> or less*  
(*private office*) *0.5 mg/m<sup>3</sup> - 5.0 mg/m<sup>3</sup>*  
CHPS 2019 Core Criteria 3.0 EQ C6.1.6 *ceiling & wall systems*

Certified Products: Architectural Wall Panels  
(see page 2 for list of certified products)

Test Date: June 22, 2022      Report No.: 2200427      Certificate No.: MAS2200427

Valid: June 2022 to June 2023



Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017  
3<sup>rd</sup> Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012  
\*outside of A2LA accreditation scope

Page 1 Of 2

3945 Lakefield Ct. · Suwanee, Ga. · 770-866-3206 · <http://www.mascertifiedgreen.com/>

# MAS Certified Green® Certificate of Compliance Low-Emitting Materials



Awarded to: **NICHIHA USA, INC. OF JOHNS CREEK, GA**  
6465 E. JOHNS CREEK CROSSING, SUITE 250: ZIP CODE: 30097

## Certified Products: Fiber Cement Siding

<u>Brick Series</u> <i>Canyon Brick**</i> <i>Modern Brick</i> <i>Plymouth Brick</i> <i>Vintage brick</i>	<u>Concrete Series</u> <i>Corbosa</i> <i>EmpireBlock™</i> <i>IndustrialBlock™</i>	<u>Designer Series</u> <i>Illumination™</i> <i>Miraia™</i> <i>Stock Illumination</i>	<u>Dimensions Series</u> <i>Novenary Tile</i> <i>Ribbed™</i>
<u>Kurastone™ Series</u> <i>LedgeStone</i> <i>StackedStone</i>	<u>Masonry Series</u> <i>Sandstone™</i>	<u>Modern Series</u> <i>ArchitecturalBlock™</i> <i>TuffBlock™</i>	<u>Wood Series</u> <i>RiftSwan</i> <i>Roughsawn™</i> <i>VintageWood™</i>

(\*\* Product tested as representative exemplar of products listed above.)

Test Date: June 22, 2022      Report No.: 2200427      Certificate No.: MAS2200427

Valid: June 2022 to June 2023



Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017      Page 2 Of 2  
3<sup>rd</sup> Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012  
\*outside of A2LA accreditation scope

3945 Lakefield Ct. · Suwanee, Ga. · 770-866-3206 · <http://www.mascertifiedgreen.com/>